



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
551037

EQUIPMENT INSPECTED

State Number: 2982	Type of Unit: Freight	Landings: 2	Manuf: SOUTHERN
Capacity: 12000	Installed: 01/30/1958	Complied: 03/14/1958	Speed: 100
Volts: 440	Floor to Floor: 1 to 2	Entrances: 1	Rope Size: 5/8
Owner: ENERGIZER CORP, 800 ALBEMARLE ROAD, ASHEBORO, NC, 28203-6263			
Occupant: ENERGIZER CORP, 800 ALBEMARLE ROAD, ASHEBORO, NC, 27203			

INSPECTION INFORMATION

Inspection Date 04/03/2008	Type Inspection Removed	Certificate Status Not Issued	Inspector 12 - Essick	County Name RANDOLPH	County Code 76
-------------------------------	----------------------------	----------------------------------	--------------------------	-------------------------	-------------------

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6 Properly land elevator.

Note Unit removed from service due to damaged drive assy. Plant plans to decommission the unit permanently.

Violations pointed out to: Maintenance

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ENERGIZER CORP, 800 ALBEMARLE ROAD, ASHEBORO, NC, 28203-6263
Occupant: ENERGIZER CORP, 800 ALBEMARLE ROAD, ASHEBORO, NC, 27203

Invoice Number
551037
State Nbr: 2982
Date: 04/03/2008
Fee: \$200