

N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
551208

EQUIPMENT INSPECTED

State Number: 17858 Type of Unit: Passenger Landings: 3 Manuf: THYSSEN KRUPP
Capacity: 2500 Installed: 04/06/1999 Complied: 04/06/1999 Speed: 100
Volts: 208 Floor to Floor: 1 to 3 Entrances: 1 Rope Size:
Owner: EAST COAST HOSPITALITY, 719 W 15TH STREET STE 11, WASHINGTON, NC, 27889
Occupant: HOLIDAY INN EXPRESS, 1113 E DIXIE DRIVE, ASHEBORO, NC, 27203

INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County Name | County Code |
|-----------------|-----------------|--------------------|-------------|-------------|-------------|
| 07/07/2008 | Routine | Re-issued | 12 - Essick | RANDOLPH | 76 |

Violation Abatement Date: 08/06/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6 Secure loose pit ladder
NEC Neutral for car lights cannot be fused
8.6 Make all pit lights function

Violations pointed out to: Sheila Herd, Front Desk

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: EAST COAST HOSPITALITY, 719 W 15TH STREET STE 11, WASHINGTON, NC,
27889
Occupant: HOLIDAY INN EXPRESS, 1113 E DIXIE DRIVE, ASHEBORO, NC, 27203

Invoice Number
551208

State Nbr: 17858
Date: 07/07/2008
Fee: \$175