



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)

Invoice Number  
**551458**

### EQUIPMENT INSPECTED

State Number: 480      Type of Unit: Freight      Landings: 5      Manuf: OTIS  
Capacity: 2000      Installed: 01/11/1946      Complied: 01/11/1946      Speed: 75  
Volts: 220      Floor to Floor: B to 3      Entrances: 2      Rope Size: 1/2  
Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287  
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203

Elevator Name: Red Gate

### INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
01/13/2009	Routine	Re-issued	12 - Essick	RANDOLPH	76

Violation Abatement Date: 02/12/2009

### VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6      Loose door track on 2nd floor

Violations pointed out to: Marilyn, Maintenance

Inspector \_\_\_\_\_

### INVOICE

No other invoice will be issued.  
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,  
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287  
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203

Invoice Number  
**551458**  
State Nbr: 480  
Date: 01/13/2009  
Fee: \$200