

N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
551460

EQUIPMENT INSPECTED

State Number: 1167 Type of Unit: Freight Landings: 2 Manuf: OTIS
Capacity: 2000 Installed: 10/11/1948 Complied: 10/11/1948 Speed: 75
Volts: 220 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 1/2
Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203

Elevator Name: Plant 3

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
01/13/2009	Routine	Re-issued	12 - Essick	RANDOLPH	76

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

NCAC Missing certificate frame screw

Violations pointed out to: Marilyn, Maintenance

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203

Invoice Number
551460
State Nbr: 1167
Date: 01/13/2009
Fee: \$200