



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
551463

EQUIPMENT INSPECTED

State Number: 1572	Type of Unit: Freight	Landings: 2	Manuf: MONARCH
Capacity: 2000	Installed: 10/26/1950	Complied: 10/26/1950	Speed: 60
Volts: 220	Floor to Floor: 1 to 2	Entrances: 1	Rope Size: 1/2
Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287			
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203			

INSPECTION INFORMATION

Inspection Date 01/13/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County Name RANDOLPH	County Code 76
-------------------------------	----------------------------	---------------------------------	--------------------------	-------------------------	-------------------

Violation Abatement Date: 02/12/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6 Loose COP guard on car
- 8.6 Make level up button function properly. Car will level up out of door zone

Violations pointed out to: Marilyn, Maintenance

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ACME MCCRARY CORP, BOX 1287, ASHEBORO, NC, 27204-1287
Occupant: ACME MCCRARY CORP, 159 NORTH ST, ASHEBORO, NC, 27203

Invoice Number
551463
State Nbr: 1572
Date: 01/13/2009
Fee: \$200