



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
551618

EQUIPMENT INSPECTED

State Number: 16142 Type of Unit: Passenger Landings: 4 Manuf: THYSSEN KRUPP
Capacity: 8000 Installed: 03/28/1996 Complied: 04/10/1996 Speed: 100
Volts: 480 Floor to Floor: 1 to 4 Entrances: 1 Rope Size: 5/8
Owner: STAR PET, 801 PINEVIEW RD, ASHEBORO, NC, 27203
Occupant: STAR PET, 801 PINEVIEW RD, ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date 03/06/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County Name RANDOLPH	County Code 76
-------------------------------	----------------------------	---------------------------------	--------------------------	-------------------------	-------------------

Violation Abatement Date: 04/05/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6 Make alarm bell function
- 8.6 Replace missing emergency car light

Violations pointed out to: John, Maintenance

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: STAR PET, 801 PINEVIEW RD, ASHEBORO, NC, 27203
Occupant: STAR PET, 801 PINEVIEW RD, ASHEBORO, NC, 27203

Invoice Number
551618
State Nbr: 16142
Date: 03/06/2009
Fee: \$200