



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
556919

EQUIPMENT INSPECTED

State Number: N7.7	Type of Unit: Freight	Landings: 2	Manuf: OTIS
Capacity: 2500	Installed: 06/05/1975	Complied: 06/05/1975	Speed: 100
Volts: 220	Floor to Floor: 1 to 2	Entrances: 2	Rope Size: 1/2
Owner: FRANCIS NOBLES, 306 RIVER RD, WASHINGTON, NC, 27889			
Occupant: DOWNTOWN RESTAURANT, 107 MAIN ST, WASHINGTON, NC, 27889			

INSPECTION INFORMATION

Inspection Date 03/31/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County Name BEAUFORT	County Code 7
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	------------------

Violation Abatement Date: 04/30/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6.1.6.2 All parts of the machinery and equipment requiring lubrication shall be lubricated with lubricants equivalent manufacturers recommendations properly fill machine

Violations pointed out to: Glenn Wetherington

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: FRANCIS NOBLES, 306 RIVER RD, WASHINGTON, NC, 27889
Occupant: DOWNTOWN RESTAURANT, 107 MAIN ST, WASHINGTON, NC, 27889

Invoice Number
556919
State Nbr: N7.7
Date: 03/31/2008
Fee: \$200