



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
557293

EQUIPMENT INSPECTED

State Number: N7.4 Type of Unit: Passenger Landings: 4 Manuf: SOUTHERN
Capacity: 2000 Installed: 06/03/1975 Complied: 06/03/1975 Speed: 300
Volts: 220 Floor to Floor: B to 3 Entrances: 1 Rope Size: 1/2
Owner: CITY OF WASHINGTON, PO BOX 1988, WASHINGTON, NC, 27889
Occupant: WASHINGTON MUNICIPAL BLDG, 100 SECOND ST, WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
10/17/2008	Routine	Re-issued	16 - Moore	BEAUFORT	7

Violation Abatement Date: 11/16/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Violations pointed out to: William in Maintenance

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CITY OF WASHINGTON, PO BOX 1988, WASHINGTON, NC, 27889
Occupant: WASHINGTON MUNICIPAL BLDG, 100 SECOND ST, WASHINGTON, NC, 27889

Invoice Number
557293
State Nbr: N7.4
Date: 10/17/2008
Fee: \$200