

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Number 559255

		EQUIPMENT INSP	ECTED			
State Number: 21244 Type of Unit: Passe				Manuf: THYSSEN KRUPP		
Capacity: 4500			Complied: 09/04/2003		Speed: 125	
Volts: 480	Floor to Floor: 1 to 2			Rope Size: 0		
	ORRECTIONAL INSTITU CORRECTIONAL INSTI					
Elevator Name: RICHMOND	BLDG INSPEC	TION INFORMATION				
Inspection Date 06/12/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County Name ANSON	County Cod 4	
Violation Abatement Date: 07/12/2008						
Notify the Elevator Bureau equipment into compliance	in writing on Corrected Viwith current codes.	olations Form when the f	following corrections	have been made in ord	er to bring your	
8.6 PERFORM ANNU	JAL PRESSURE RELIEF	VALVE TEST				
iolations pointed out to: REP- ANDY BREWER			Inspector			
		INVOICE				
	No other invoice wi					
-	a 30 days from date of invo	-		τ	NI1	
Return this stub with paym 1101 Mail Service Center,	nent to: NC Department of I Raleigh, NC 27699-1101	Labor, Budget and Purcha	asing Division,		e Number 9255	

Occupant: LANESBORO CORRECTIONAL INSTITUTION, 552 PRISON CAMP RD,

Owner: LANESBORO CORRECTIONAL INSTITUTION, P.O.BOX 280, POLKTON, NC,

POLKTON, NC, 28135

28135

559255 State Nbr: 21244

Date: 06/12/2008 Fee: \$175