



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
566938

EQUIPMENT INSPECTED

State Number: H1944 Type of Unit: Hand Lift Landings: 2 Manuf: GARAVENTA
Capacity: 750 Installed: 05/14/2008 Complied: Speed: 10
Volts: 120 Floor to Floor: 1 to 2 Entrances: 2 Rope Size:
Owner: BRUNSWICK COMMUNITY COLLEGE, 50 COLLEGE ROAD, SUPPLY, NC, 28462
Occupant: ODELL WILLIAMSON AUDITORIUM, 50 COLLEGE ROAD, SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
05/14/2008	New	Not Issued	48 - Martin	BRUNSWICK	10

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

A 18 SECTION A 18 - CLEARENCE BETWEEN WALL AND CAB NOT MET AT TOP OF SHAFT. [LESS THAN 1/4 INCH.].

Violations pointed out to: ERIC

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: BRUNSWICK COMMUNITY COLLEGE, 50 COLLEGE ROAD, SUPPLY, NC, 28462
Occupant: ODELL WILLIAMSON AUDITORIUM, 50 COLLEGE ROAD, SUPPLY, NC, 28462

Invoice Number
566938

State Nbr: H1944
Date: 05/14/2008
Fee: \$200