



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
566957

EQUIPMENT INSPECTED

State Number: 17013 Type of Unit: Passenger Landings: 4 Manuf: THYSSEN KRUPP
Capacity: 2500 Installed: 11/24/1997 Complied: 01/09/1998 Speed: 150
Volts: 480 Floor to Floor: 1 to 4 Entrances: 1 Rope Size:
Owner: BENCHMARK MANAGEMENT, C/O JANE WHIELDON, NORTH MYRTLE BEACH, SC, 29597
Occupant: WINDJAMMER CONDO, W 2ND ST, OCEAN ISLE, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
05/27/2008	Routine	Re-issued	48 - Martin	BRUNSWICK	10

Violation Abatement Date: 06/16/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.

Violations pointed out to: UNAVAILABLE

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: BENCHMARK MANAGEMENT, C/O JANE WHIELDON, NORTH MYRTLE BEACH,
SC, 29597
Occupant: WINDJAMMER CONDO, W 2ND ST, OCEAN ISLE, NC, 28469

Invoice Number
566957

State Nbr: 17013
Date: 05/27/2008
Fee: \$175