



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)

Invoice Number  
**567001**

### EQUIPMENT INSPECTED

State Number: 15582	Type of Unit: Freight	Landings: 2	Manuf: OTIS
Capacity: 12000	Installed: 11/23/1994	Complied: 12/05/1994	Speed: 75
Volts: 480	Floor to Floor: 1 to 2	Entrances: 1	Rope Size:
Owner: CAROLINA FOOD PROCESSORS, NC HWY 87N, TAR HEEL, NC, 28392			
Occupant: CAROLINA FOOD PROCESSORS, PO BOX 447, SMITHFIELD, NC, 27577			

### INSPECTION INFORMATION

Inspection Date 07/02/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BLADEN	County Code 9
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------------	------------------

Violation Abatement Date: 08/01/2008

### VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6.4.13.1 All landing and car-door or gate mechanical and electrical components shall be maintained to ensure safe and proper operation. PROVIDE PULL STRAP'S ON SHAFT DOOR'S.
- 8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR CLOSER ON MOTOR ROOM DOOR TO CLOSE AND LOCK ON IT'S OWN.
- 8.11.2.3 Preform a 5 year full load safety test
- 8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.
- 8.6.4.13.2 Where a power-operated horizontally sliding door is closed by momentary pressure or by automatic means, the closing kinetic energy and closing force shall be maintained to proper levels. DOOR CLOSE BUTTON INOPERATIVE.
- 8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. ALARM BELL INOPERATIVE.

Violations pointed out to: BILL JESSUP

Inspector \_\_\_\_\_

### INVOICE

No other invoice will be issued.  
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Invoice Number

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,  
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CAROLINA FOOD PROCESSORS, NC HWY 87N, TAR HEEL, NC, 28392  
Occupant: CAROLINA FOOD PROCESSORS, PO BOX 447, SMITHFIELD, NC, 27577

---

567001

State Nbr: 15582

Date: 07/02/2008

Fee: \$175