



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
567062

EQUIPMENT INSPECTED

State Number: 21687 Type of Unit: Passenger Landings: 0 Manuf: RENAME
Capacity: 2100 Installed: 05/29/2003 Complied: 06/11/2003 Speed: 0
Volts: 0 Floor to Floor: . to . Entrances: 0 Rope Size: .
Owner: CROW CREEK, 250 CROW CREEK DRIVE, CALABASH, NC, 28469
Occupant: CROW CREEK CONDO, 250 S. CROW CREEK DR., CALABASH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
08/07/2008	Routine	Re-issued	48 - Martin	BRUNSWICK	10

Violation Abatement Date: 09/06/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.7.1 Clean the hoistway(s) (pits) of all debris.

Violations pointed out to: JENNIFER

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CROW CREEK, 250 CROW CREEK DRIVE, CALABASH, NC, 28469
Occupant: CROW CREEK CONDO, 250 S. CROW CREEK DR., CALABASH, NC, 28469

Invoice Number
567062

State Nbr: 21687
Date: 08/07/2008
Fee: \$175