

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Numbe	1
567151	

EQUIPMENT INSPECTED							
State Number: 23201 Type of Unit:		Passenger Landings: 2			Manuf: OTIS		
Capacity: 2500	Installed: 11/	17/2005	5 Complied: 11/17/2005		Speed: 100		
Volts: 208 Floor to Floor					Rope Size:		
	LAND COMPANY, 1103 EK COMMONS, 1105 NE						
		INSPECTION INFO	RMATION				
Inspection Date 10/13/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Cod		
Violation Abatement	Date: 11/12/2008	VIOLATIONS FOU	ND				
Notify the Elevator Bureau quipment into compliance	u in writing on Corrected Ve with current codes.	Violations Form when the	following corrections	s have been made in o	order to bring your		
Emergency op INOPERATIV	eration of signaling device E.	s,lighting, communication	, and ventilation, sha	ıll be maintained. EM	ER. PHONE		
8.11.3.2.1 Preform the an	nual relief valve test						
iolations pointed out to:	VINNY			Inspector			
		INVOICE					

No other invoice will be issued. If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CROSS CREEK LAND COMPANY, 1105 NEW POINTE BLVD, LELAND, NC, 28451 Occupant: CROSS CREEK COMMONS, 1105 NEW POINTE BLVD, LELAND, NC, 28451

Invoice Number 567151

State Nbr: 23201 Date: 10/13/2008 Fee: \$175