



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
567183

EQUIPMENT INSPECTED

State Number: 22646 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 4500 Installed: 04/27/2005 Complied: 04/27/2005 Speed: 80
Volts: 208 Floor to Floor: 1 to 2 Entrances: 1 Rope Size:
Owner: KEN CARLOUGH, 1430 COMMONWEALTH DR. SUITE 102, WILMINGTON, NC, 28403
Occupant: BRUNSWICK MEDICAL CAMPUS, 346 OCEAN HIGHWAY WEST, SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date 11/14/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Code 10
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------------	-------------------

Violation Abatement Date: 12/14/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. ALARM BELL INOPERATIVE WHEN ALARM BUTTON PUSHED.
- 8.11.3.2.1 Preform the annual relief valve test

Violations pointed out to: unavailable

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: KEN CARLOUGH, 1430 COMMONWEALTH DR. SUITE 102, WILMINGTON, NC,
28403
Occupant: BRUNSWICK MEDICAL CAMPUS, 346 OCEAN HIGHWAY WEST, SUPPLY, NC,
28462

Invoice Number
567183

State Nbr: 22646
Date: 11/14/2008
Fee: \$175