



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)

Invoice Number  
**567203**

### EQUIPMENT INSPECTED

State Number: H1321      Type of Unit: Hand Lift      Landings: 2      Manuf: THYSSEN KRUPP  
Capacity: 750      Installed: 10/04/2002      Complied: 10/04/2002      Speed: 15  
Volts: 115      Floor to Floor: 1 to 2      Entrances: 2      Rope Size: 0  
Owner: WINDSOR METHODIST CHURCH, 6292 OLD FAYETTEVILLE RD., AMMON, NC, 28441  
Occupant: WINDSOR METHODIST CHURCH, 12880 NC HWY 242, AMMON, NC, 28441

### INSPECTION INFORMATION

Inspection Date 11/21/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BLADEN	County Code 9
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------------	------------------

Violation Abatement Date: 12/11/2008

### VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

### INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,  
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: WINDSOR METHODIST CHURCH, 6292 OLD FAYETTEVILLE RD., AMMON, NC,  
28441  
Occupant: WINDSOR METHODIST CHURCH, 12880 NC HWY 242, AMMON, NC, 28441

Invoice Number  
**567203**

State Nbr: H1321  
Date: 11/21/2008  
Fee: \$65