

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm Invoice Number 567224

EQUIPMENT INSPECTED					
State Number: 13283 Type of Unit:		Passenger Landings: 3			Manuf: OTIS
Capacity: 2500	Installed: 08/	17/1989	Complied: 07/19/1995		Speed: 125
Volts: 208	: 208 Floor to Floor:		Entrances: 1		Rope Size:
		ASWELL BEACH RD, C			
Decupant: BAPTIST ST	ATE CONVENTION, 100	CASWELL BEACH RD	, CASWELL BEAC	H, NC, 28461 	
		INSPECTION INFO	RMATION		
Inspection Date 12/03/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Code
Violation Abatement Date: 01/02/2009		VIOLATIONS FOUR			
Notify the Elevator Bureau quipment into complianc	e with current codes.	Violations Form when the	-		order to bring your
	maintain door closers, who the annual relief valve test	ere required. REPAIR DO	OR TO CLOSE ANI	D LOCK ON IT'S OV	WN.
iolations pointed out to: DONNIE				Inspector	
		INVOICE			

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: BAPTIST STATE CONVENTION, 100 CASWELL BEACH RD, CASWELL BEACH, NC, $28461\,$

Occupant: BAPTIST STATE CONVENTION, 100 CASWELL BEACH RD, CASWELL BEACH,

NC, 28461

Invoice Number 567224

State Nbr: 13283 Date: 12/03/2008 Fee: \$175