



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)

Invoice Number  
**567229**

### EQUIPMENT INSPECTED

State Number: 20696	Type of Unit: Passenger	Landings: 3	Manuf: CANTON
Capacity: 2000	Installed: 07/22/2002	Complied: 07/24/1992	Speed: 100
Volts: 208	Floor to Floor: 1 to 3	Entrances: 1	Rope Size: 0
Owner: CLEAR WATER PLACE, 1620 GOLEY HEWETT RD., BOLIVIA, NC, 28422			
Occupant: CLEAR WATER PLACE, 1620 GOLEY HEWETT RD., BOLIVIA, NC, 28422			

### INSPECTION INFORMATION

Inspection Date 12/04/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Code 10
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------------	-------------------

Violation Abatement Date: 12/24/2008

### VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.1.6 General Maintenance Methods and Procedures LIGHT'S OUT IN MOTOR ROOM.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

### INVOICE

No other invoice will be issued.  
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,  
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CLEAR WATER PLACE, 1620 GOLEY HEWETT RD., BOLIVIA, NC, 28422  
Occupant: CLEAR WATER PLACE, 1620 GOLEY HEWETT RD., BOLIVIA, NC, 28422

Invoice Number  
**567229**

State Nbr: 20696  
Date: 12/04/2008  
Fee: \$175