

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm Invoice Number 567314

EQUIPMENT INSPECTED					
State Number: 26346	Type of Unit: Passenger		Landings: 2	Manuf: SCHINDLER	
Capacity: 2100	Installed: 01/28/2009 Floor to Floor: 1 to 2		Complied:	Speed: 125 Rope Size:	
Volts: 208			Entrances: 1		
	ING SPRING LAKES, 9 E				
_	RING LAKES TOWN HA		IGS ROAD, BOILIN	G SPRING LAKES, NO	C, 28461
		INSPECTION INFO			
Inspection Date 01/28/2009	Type Inspection New	Not Issued	Inspector 48 - Martin		10
Violation Abatement Date: 02/27/2009		VIOLATIONS FOUN			
700.18 EMER. POWER	NO LED JEWEL ON F	IRST FL. RISER TO IND	ICATE ELEVATOR	RUNNING ON EMER	R. POWER.
iolations pointed out to: MIKE JOHNSON [SCHINDLER]			Inspector		
		INVOICE			
If not paid with	No other invoice v		mes invalid		

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: CITY OF BOILING SPRING LAKES, 9 E BOILING SPRING ROAD, BOILING SPRING LAKES, NC, $28461\,$

Occupant: BOILING SPRING LAKES TOWN HALL, 9 E BOILING SPRINGS ROAD, BOILING

SPRING LAKES, NC, 28461

Invoice Number 567314

State Nbr: 26346 Date: 01/28/2009 Fee: \$200