

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice	Number			
567430				

		EQUIPMENT INSP	ECTED		
State Number: 12433 Type of Unit: Passer		ger Landings: 2		Manuf: THYSSEN KRUPP	
Capacity: 2100	y: 2100 Installed: 01/20/1988 Complied: 01/26		1: 01/26/1988	Speed: 100	
Volts: 480	Floor to Floor: 1 to 2	Entrance	s: 1	Rope Size:	
	OMMUNITY COLLEGE, PO				
Occupant: BRUNSWICK	COMM COLLEGE, 50 COL	LEGE RD. HWY. 17	BYPASS, SUPPLY	, NC, 28462	
		INSPECTION INFOR	MATION		
Inspection Date 03/23/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Cod 10
Violation Abatement D	Date: 04/12/2009	VIOLATIONS FOUN	D		
quipment into compliance 3.6.1.6 General Maintena 3.6.4.15 Emergency opera	ance Methods and Procedures.	PROVIDE MISSING	CEILING TILES I	N MOTOR ROOM.	
INOPERATIVE.					TIOTAL
					110112
iolations pointed out to:				Inspector	

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: BRUNSWICK COMMUNITY COLLEGE, PO BOX 30, SUPPLY, NC, 28462

Occupant: BRUNSWICK COMM COLLEGE, 50 COLLEGE RD. HWY. 17 BYPASS, SUPPLY,

NC, 28462

Invoice Number 567430

State Nbr: 12433 Date: 03/23/2009 Fee: \$175