



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
567442

EQUIPMENT INSPECTED

State Number: 21072 Type of Unit: Passenger Landings: 3 Manuf: THYSSEN KRUPP
Capacity: 2000 Installed: 05/23/2002 Complied: 05/23/2002 Speed: 100
Volts: 208 Floor to Floor: 1 to 3 Entrances: 1 Rope Size:
Owner: MICROTTEL INN, 4646 EAST COAST LANE NW, SHALOTTE, NC, 28459
Occupant: MICROTTEL INN, 4646 EAST COAST LANE NW, SHALOTTE, NC, 28559

INSPECTION INFORMATION

Inspection Date 03/25/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County Name BRUNSWICK	County Code 10
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------------	-------------------

Violation Abatement Date: 04/14/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6.4.7.1 Clean the hoistway(s) (pits) of all debris. CLEAN PIT & REPLACE BLOWN LIGHT.
- 8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.

Violations pointed out to: SHARON WRIGHT

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: MICROTTEL INN, 4646 EAST COAST LANE NW, SHALOTTE, NC, 28459
Occupant: MICROTTEL INN, 4646 EAST COAST LANE NW, SHALOTTE, NC, 28559

Invoice Number
567442
State Nbr: 21072
Date: 03/25/2009
Fee: \$175