



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
575417

EQUIPMENT INSPECTED

State Number: 19643 Type of Unit: Passenger Landings: 3 Manuf: THYSSEN KRUPP
Capacity: 2500 Installed: 01/05/2001 Complied: 01/05/2001 Speed: 100
Volts: 200 Floor to Floor: 1 to 3 Entrances: 1 Rope Size:
Owner: B.C. PARKER REAL ESTATE, 336-226-8411, GREENSBORO, NC, 27429
Occupant: DELANEY CROSSING #2, 2223 DELANEY DR, BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
09/30/2008	Routine	Re-issued	36 - Kirkman	ALAMANCE	1

Violation Abatement Date: 10/30/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Violations pointed out to: OFFICE

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: B.C. PARKER REAL ESTATE, 336-226-8411, GREENSBORO, NC, 27429
Occupant: DELANEY CROSSING #2, 2223 DELANEY DR, BURLINGTON, NC, 27215

Invoice Number
575417

State Nbr: 19643
Date: 09/30/2008
Fee: \$175