

27215

BURLINGTON, NC, 27215

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm Invoice Number 575555

State Nbr: 15314

Date:

Fee:

01/08/2009

\$200

EQUIPMENT INSPECTED						
State Number: 15314	Type of Unit:	Passenger	Landings: 4		Manuf: KONE	
Capacity: 4500	Floor to Floor: LL to 3		Complied: 05/11/1995	995	Speed: 350	
7olts: 480			Entrances: 1		Rope Size: 5/8	
) HERMITAGE RD, BUR L CTR, 1230 HUFFMAN I				
		INSPECTION INFO				
Inspection Date 01/08/2009	Type Inspection Routine		Inspector 36 - Kirkman			
Violation Abatement	Date: 02/07/2009	VIOLATIONS FOU	ND			
otify the Elevator Burea uipment into complianc		Violations Form when the	following corrections	have been made in	order to bring your	
.6.4.8.1 Floors and	i machinery spaces shall t	be kept free of, dirt, rubbis	h, oil, and grease.			
olations pointed out to: DON SCOTT			Inspector			
		INVOICI	E			
If not paid with	No other invoice in 30 days from date of in	will be issued.	omes invalid.			
Return this stub with pay: 101 Mail Service Center		Inv	oice Number 575555			

Owner: ALAMANCE HEALTH SERVICES, 730 HERMITAGE RD, BURLINGTON, NC,

Occupant: ALAMANCE REGIONAL MEDICAL CTR, 1230 HUFFMAN MILL RD,