N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
577612

EQUIPMENT INSPECTED

State Number: 21597	Type of Unit: Passenger	Landings: 2	Manuf: ASHEVILLE
Capacity: 2500	Installed: 08/14/2003	Complied: 08/14/2003	Speed: 95
Volts: 480	Floor to Floor: 1 to 2	Entrances: 1	Rope Size: 0

Owner: ASHEVILLE CHRISTIAN ACADEMY, PO BOX 1089, SWANNANOA, NC, 28778
Occupant: ASHEVILLE CHRISTIAN ACADEMY, 74 RIVERWOOD ROAD, SWANNANOA, NC, 28778

Elevator Name: ELEVATOR EAST

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
07/31/2008	Routine	Re-issued	24 - Moore	BUNCOMBE	11 B

Violation Abatement Date: 08/30/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.15 Emergency operation of signaling devices, communication, shall be maintained. 911 operator could barely hear me and they are wiring connectors pertruding from the C.O.P..Replace in C.O.P.. Annoucement keeps repeating.

Violations pointed out to: Mark Brant / 828-581-2200

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ASHEVILLE CHRISTIAN ACADEMY, PO BOX 1089, SWANNANOA, NC, 28778
Occupant: ASHEVILLE CHRISTIAN ACADEMY, 74 RIVERWOOD ROAD, SWANNANOA, NC, 28778

Invoice Number
577612
State Nbr: 21597
Date: 07/31/2008
Fee: $175