



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
577613

EQUIPMENT INSPECTED

State Number: 21596 Type of Unit: Passenger Landings: 2 Manuf: ASHEVILLE
Capacity: 2500 Installed: 08/14/2003 Complied: 08/14/2003 Speed: 95
Volts: 480 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: ASHEVILLE CHRISTIAN ACADEMY, PO BOX 1089, SWANNANOVA, NC, 28778
Occupant: ASHEVILLE CHRISTIAN ACADEMY, 74 RIVERWOOD ROAD, SWANNANOVA, NC, 28778

Elevator Name: ELEVATOR WEST

INSPECTION INFORMATION

Inspection Date 07/31/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County Name BUNCOMBE	County Code 11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 08/30/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.15 Emergency operation of signaling devices, communication, shall be maintained. Volume O.K., but announcement keeps repeating.

Violations pointed out to: Mark Brant / 828-581-2200

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ASHEVILLE CHRISTIAN ACADEMY, PO BOX 1089, SWANNANOVA, NC, 28778
Occupant: ASHEVILLE CHRISTIAN ACADEMY, 74 RIVERWOOD ROAD, SWANNANOVA,
NC, 28778

Invoice Number
577613

State Nbr: 21596
Date: 07/31/2008
Fee: \$175