



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
577785

EQUIPMENT INSPECTED

State Number: 22572	Type of Unit: Passenger	Landings: 9	Manuf: OTIS
Capacity: 2500	Installed: 04/26/2005	Complied: 09/14/2005	Speed: 200
Volts: 208	Floor to Floor: 1 to 9	Entrances: 1	Rope Size: .
Owner: 21 BATTERY PARK L.L.C., C/O IPM CORP./ ATTN: TAMMY JONES, ARDEN, NC, 28704-0580			
Occupant: 21 BATTERY PARK CONDOMINIUM, 21 BATTERY PARK, ASHEVILLE, NC, 28801			

Elevator Name: ELEVATOR # 1

INSPECTION INFORMATION

Inspection Date 10/24/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County Name BUNCOMBE	County Code 11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 11/23/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.15 Take steps to place the car emergency light in proper working order.

Violations pointed out to: Mailed to Owner Rep.

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: 21 BATTERY PARK L.L.C., C/O IPM CORP./ ATTN: TAMMY JONES, ARDEN, NC,
28704-0580
Occupant: 21 BATTERY PARK CONDOMINIUM, 21 BATTERY PARK, ASHEVILLE, NC,
28801

Invoice Number
577785

State Nbr: 22572
Date: 10/24/2008
Fee: \$200