

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Number 579217

	EQUIPMENT INSPECTED						
State Number: 25777		Type of I	Type of Unit: Passenger		igs: 3	Manuf: TKE	
Capacity: 5000		Installed: 03/28/2008		Complied:		Speed: 125	
Volts: 480		Floor to Floor: 1 to 3		Entrances: 2		Rope Size:	
			101 W WORTHINGTON A		EVILLE, NC, 2880	1	
Occup	ant: BILTMORE V	'ILLAGE, 10 BROOK ST	REET, ASHEVILLE, NC,	28801			
Elevator Name: B		INSF	T				
04/03/2008		Type Inspection Compliance	Not Issued	Inspector 17 - White	BUNCOMBE	11 A	
Vio		Date: 04/03/2008					
	ent into compliance	in writing on Corrected Ve with current codes.	iolations Form when the fo	ollowing corrections	have been made in	order to bring your	
3.6.5 nec	Provide proper h.v.a.c. according to Manufacture in (a) and (b) units for machine room. cover all exposed wires in raceway on top cars.						
3.6.5	Provide proper fire rating at top of shaft on elev. (b) recaulk at top.						
3.6.5	Provide level entrance on ground floor to elevator (b)						
3.6.5	Provide key locks to meet seimic code on emergency exits on top of cars (A) AND (B).						
3.6.5	Finish handrails i	Finish handrails installation car (A) and lower cab vents.					
iolations pointed out to: T.K.E.				Inspector			
			INVOICE				
		No other invoice v	vill be issued				

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: HISTORIC BILTMORE VILLAGE LLC, 101 W WORTHINGTON AVE STE 20,

ASHEVILLE, NC, 28801

Occupant: BILTMORE VILLAGE, 10 BROOK STREET, ASHEVILLE, NC, 28801

Invoice Number 579217

State Nbr: 25777 04/03/2008 Date: \$200 Fee: