



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)

Invoice Number  
**579435**

### EQUIPMENT INSPECTED

State Number: 17494	Type of Unit: Passenger	Landings: 3	Manuf: ACE
Capacity: 2100	Installed: 08/05/1998	Complied: 08/05/1998	Speed: 100
Volts: 208	Floor to Floor: G to 2	Entrances: 1	Rope Size:
Owner: ARDEN FIRST BAPTIST CHURCH, 3839 SWEETEN CREEK RD, ARDEN, NC, 28704			
Occupant: ARDEN FIRST BAPTIST CHURCH, 3839 SWEETEN CREEK RD, ARDEN, NC, 28704			

### INSPECTION INFORMATION

Inspection Date 07/24/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County Name BUNCOMBE	County Code 11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 08/23/2008

### VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.1	Test all elevator smoke detectors for 2008.
8.3.3.2	Repair car flooring.

Violations pointed out to: office

Inspector \_\_\_\_\_

### INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,  
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ARDEN FIRST BAPTIST CHURCH, 3839 SWEETEN CREEK RD, ARDEN, NC, 28704  
Occupant: ARDEN FIRST BAPTIST CHURCH, 3839 SWEETEN CREEK RD, ARDEN, NC, 28704

Invoice Number  
**579435**

State Nbr: 17494  
Date: 07/24/2008  
Fee: \$175