



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
579582

EQUIPMENT INSPECTED

State Number: 6775 Type of Unit: Passenger Landings: 8 Manuf: WESTINGHOUSE
Capacity: 2500 Installed: 11/24/1970 Complied: 02/02/1971 Speed: 350
Volts: 550 Floor to Floor: G to 7 Entrances: 1 Rope Size: 1/2
Owner: ASHEVILLE BUNCOMBE TECH COLL, 340 VICOTRIA RD, ASHEVILLE, NC, 28801
Occupant: ASHEVILLE BUNCOMBE COLL, 1459 SANDHILL RD., CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date 10/02/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County Name BUNCOMBE	County Code 11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 11/01/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.3 Cover or guard car interior lights

Violations pointed out to: Eddie

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ASHEVILLE BUNCOMBE TECH COLL, 340 VICOTRIA RD, ASHEVILLE, NC,
28801
Occupant: ASHEVILLE BUNCOMBE COLL, 1459 SANDHILL RD., CANDLER, NC, 28715

Invoice Number
579582

State Nbr: 6775
Date: 10/02/2008
Fee: \$200