



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
579583

EQUIPMENT INSPECTED

State Number: 24208	Type of Unit: Passenger	Landings: 2	Manuf: AEC
Capacity: 2100	Installed: 08/31/2006	Complied: 08/31/2006	Speed: 100
Volts: 575	Floor to Floor: 1 to 2	Entrances: 1	Rope Size: 0
Owner: ASHEVILLE BUNCOMBE TECH COL, 1459 SAND HILL ROAD, ASHEVILLE, NC, 28715			
Occupant: HAYNES SMALL BUSINESS CENTER, 1459 SAND HILL ROAD, ASHEVILLE, NC, 28715			

INSPECTION INFORMATION

Inspection Date 10/02/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County Name BUNCOMBE	County Code 11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 11/01/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.

Violations pointed out to: Eddie

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ASHEVILLE BUNCOMBE TECH COL, 1459 SAND HILL ROAD, ASHEVILLE, NC,
28715

Occupant: HAYNES SMALL BUSINESS CENTER, 1459 SAND HILL ROAD, ASHEVILLE,
NC, 28715

Invoice Number
579583

State Nbr: 24208
Date: 10/02/2008
Fee: \$175