



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
579688

EQUIPMENT INSPECTED

State Number: 13203	Type of Unit: Passenger	Landings: 3	Manuf: ASHEVILLE
Capacity: 2000	Installed: 02/01/1990	Complied: 02/01/1990	Speed: 100
Volts: 480	Floor to Floor: G to 3	Entrances: 1	Rope Size:
Owner: ARBORETUM BUILDING, WESLEY BRANCH RD, ASHEVILLE, NC, 28806			
Occupant: ARBORETUM BUILDING, WESLEY BRANCH RD, ASHEVILLE, NC, 28806			

INSPECTION INFORMATION

Inspection Date 11/14/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County Name BUNCOMBE	County Code 11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	-------------------------	---------------------

Violation Abatement Date: 12/14/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.4.15 Take steps to place the car emergency light in proper working order. (telephone, ventilation)

Violations pointed out to: rick

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ARBORETUM BUILDING, WESLEY BRANCH RD, ASHEVILLE, NC, 28806
Occupant: ARBORETUM BUILDING, WESLEY BRANCH RD, ASHEVILLE, NC, 28806

Invoice Number
579688

State Nbr: 13203
Date: 11/14/2008
Fee: \$175