



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
581595

EQUIPMENT INSPECTED

State Number: 11828 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2100 Installed: 10/01/1986 Complied: 10/01/1986 Speed: 100
Volts: 240 Floor to Floor: 1 to 2 Entrances: 1 Rope Size:
Owner: ALLEGHANY COUNTY, PO BOX 416, SPARTA, NC, 28675
Occupant: ALLEG CO / SR CITIZEN CTR, MAIN ST, SPARTA, NC, 28675

INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County Name | County Code |
|-----------------|-----------------|--------------------|-------------|-------------|-------------|
| 12/16/2008 | Routine | Re-issued | 7 - Hoffman | ALLEGHANY | 3 |

Violation Abatement Date: 01/15/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST

Violations pointed out to: LARRY DAVIS 336-372-2010

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ALLEGHANY COUNTY, PO BOX 416, SPARTA, NC, 28675
Occupant: ALLEG CO / SR CITIZEN CTR, MAIN ST, SPARTA, NC, 28675

Invoice Number
581595
State Nbr: 11828
Date: 12/16/2008
Fee: \$175