



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
581599

EQUIPMENT INSPECTED

State Number: 24155 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2100 Installed: 10/30/2006 Complied: 10/30/2006 Speed: 110
Volts: 208 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: ALLEGHENY COUNTY, 90 S MAIN STREET, SPARTA, NC, 29063
Occupant: ALLEGHENYCOUNTY COURT HOUSE, 12 N MAIN STREET, SPARTA, NC, 29063

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
12/16/2008	Routine	Re-issued	7 - Hoffman	ALLEGHANY	3

Violation Abatement Date: 01/15/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6 EMPTY OIL CATCH CAN IN THE PIT AND STOP ANY EXISTING LEAKS

Violations pointed out to: LARRY DAVIS 336-372-2010

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ALLEGHENY COUNTY, 90 S MAIN STREET, SPARTA, NC, 29063
Occupant: ALLEGHENYCOUNTY COURT HOUSE, 12 N MAIN STREET, SPARTA, NC,
29063

Invoice Number
581599

State Nbr: 24155
Date: 12/16/2008
Fee: \$175