



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593394

EQUIPMENT INSPECTED

State Number: 8962 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2000 Installed: 06/02/1977 Complied: 06/02/1977 Speed: 100
Volts: 220 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: ESEECOLA LODGE, P.O BOX 99, LINVILLE, NC, 28646
Occupant: ESEECOLA LODGE CLUBHOUSE, 83 ROSEBORO ROAD, LINVILLE, NC, 28646

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|----------------------|------------------|
| Inspection Date 06/11/2008 | Type Inspection Routine | Certificate Status Re-issued | Inspector 4 - Henegar | County Name AVERY | County Code 6 |
|-------------------------------|----------------------------|---------------------------------|--------------------------|----------------------|------------------|

Violation Abatement Date: 06/21/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

- 8.6.1.4.2 Take steps to provide updated maintenace records available upon request to elevator personnel. (2nd Notice)
- 8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid. (2nd Notice)
- 8.11.2.1.2 Take steps to provide flame spread rating on carpet in elevator.
- 8.6.4.7.1 Take steps to remove oil and oil dry from elevator pit. (2nd Notice)
- 8.6.4.8.1 Take steps to provide lighting to access machine room. (2nd Notice)
- 8.11.2.1.2 Take steps to perfom annual fire extinguisher inspection located in machine room. (2nd Notice)
- 8.11.3.2.1 Take steps to perform the annual relief valve test. (2nd Notice)
- 8.6.4.8.1 Machinery spaces shall be kept free of dirt, rubbish. (2nd Notice)
- 8.6.5.7 Provide an oil use log maintained the machine room for systems where the part of cylinder and/or piping is not exposed for visible inspection. (2nd Notice)

Violations pointed out to: John Blaeubum # 828-733-4311

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ESEECOLA LODGE, P.O BOX 99, LINVILLE, NC, 28646
Occupant: ESEECOLA LODGE CLUBHOUSE, 83 ROSEBORO ROAD, LINVILLE, NC, 28646

Invoice Number
593394

State Nbr: 8962
Date: 06/11/2008
Fee: \$175

