

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Number 593426

EQUIPMENT INSPECTED					
		Passenger 06/2003	Landings: 3 Complied: 08/12/2003 Entrances: 1		Manuf: OTIS Speed: 125 Rope Size: 0
Volts: 208	Floor to Floor: 1 to 3				
	PRESBYTERIAN, 420 CO K PRESBYTERIAN, 420			4	
		INSPECTION INFO	RMATION		
Inspection Date 06/18/2008	Type Inspection Routine			County Name AVERY	
Violation Abatement	Date: 07/18/2008	VIOLATIONS FOU	ND		
Notify the Elevator Burea equipment into complianc		Violations Form when the	-	have been made in	order to bring your
8.11.3.1.5 Take steps to	o remove wiring and electr			operation of elevat	or
3.11.3.1.4 Take steps to	install missing hall floor	numbers			
3.11.3.1.5 Take steps to	Install sump wiring per n	ational electrical code.			
8.11.3.1.1 Take steps to	install guards and end cap	os on car intior lights			
iolations pointed out to:	Jim King # 828-387-2258			Inspector	
		INVOICE	E		
If not paid with	No other invoice vin 30 days from date of inv		omes invalid		
Return this stub with pay	ment to: NC Department o	f Labor, Budget and Purc		11	oice Number 593426

06/18/2008 \$175

State Nbr: 21513 Date: Fee:

28604

1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: BANNER ELK PRESBYTERIAN, 420 COLLEGE DRIVE, BANNER ELK, NC, 28604

Occupant: BANNER ELK PRESBYTERIAN, 420 COLLEGE DRIVE, BANNER ELK, NC,