



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593428

EQUIPMENT INSPECTED

State Number: 21707	Type of Unit: Passenger	Landings: 3	Manuf: OTIS
Capacity: 2500	Installed: 05/20/2003	Complied: 05/21/2003	Speed: 125
Volts: 208	Floor to Floor: 1 to 3	Entrances: 1	Rope Size: 0
Owner: DIAMOND CREEK, LLC, P.O. BOX 2216, BANNER ELK, NC, 28604			
Occupant: DIAMOND CREEK CLUBHOUSE, 1552 ROBBINS ROAD, BANNER ELK, NC, 28604			

INSPECTION INFORMATION

Inspection Date 06/18/2008	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County Name AVERY	County Code 6
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------------	------------------

Violation Abatement Date: 07/18/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.11.2.2.2 Take steps to perform an annual no load safety test and provide proper tags.

Violations pointed out to: Ed Shell # 828-898-1800

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: DIAMOND CREEK, LLC, P.O. BOX 2216, BANNER ELK, NC, 28604
Occupant: DIAMOND CREEK CLUBHOUSE, 1552 ROBBINS ROAD, BANNER ELK, NC,
28604

Invoice Number
593428

State Nbr: 21707
Date: 06/18/2008
Fee: \$175