



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593686

EQUIPMENT INSPECTED

State Number: 10465 Type of Unit: Passenger Landings: 11 Manuf: THYSSEN KRUPP
Capacity: 2500 Installed: 10/07/1983 Complied: 10/04/2006 Speed: 350
Volts: 208 Floor to Floor: L to 11 Entrances: 1 Rope Size: 1/2
Owner: SUGAR TOP HOMEOWNERS, 303 SUGAR TOP DRIVE, BANNER ELK, NC, 28604
Occupant: SUGAR TOP RESORT, 303 SUGAR TOP DRIVE, BANNER ELK, NC, 28604

Elevator Name: # 1

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
10/06/2008	Routine	Re-issued	4 - Henegar	AVERY	6

Violation Abatement Date: 11/05/2008

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.11.2.1.2	Take steps to install 5 year full load test tag.
8.11.2.1.5	Take steps to remove all debris from pit.
8.11.2.1.2	Take steps to perform annual fire extinguisher inspection.
8.11.2.1.5	Take steps to repair pit lighting and install glass globe.

Violations pointed out to: Dennis Lacey # 828-898-5226

Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: SUGAR TOP HOMEOWNERS, 303 SUGAR TOP DRIVE, BANNER ELK, NC, 28604
Occupant: SUGAR TOP RESORT, 303 SUGAR TOP DRIVE, BANNER ELK, NC, 28604

Invoice Number
593686

State Nbr: 10465
Date: 10/06/2008
Fee: \$200