

28657

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Number 593964

		EQUIPMENT INSPI	ECTED			
State Number: 13850 Type of Unit: Passe Capacity: 2100 Installed: 10/22/19 Volts: 208 Floor to Floor: 1 to Owner: AVERY COUNTY, P.O. BOX 640, NEWI Occupant: AVERY COUNTY OFFICE BLDG., 17		Complied Entrances O, NC, 28657			Manuf: THYSSEN KRUPP Speed: 100 Rope Size: 0	
	Γ	NSPECTION INFOR	MATION			
02/11/2009	Routine	Re-issued	4 - Henegar	County Name AVERY	6	
	Date: 03/13/2009 V	/IOLATIONS FOUNI				
Notify the Elevator Bureau quipment into compliance	in writing on Corrected Violat with current codes.	ions Form when the fo	llowing corrections l	have been made in order	to bring your	
3.11.3.1.1 Take	e steps to provide proper operati	on of door open butto				
iolations pointed out to:	Joe Trivett # 828-387-0072			Inspector		
iolations pointed out to:	Joe 1rivett # 828-387-0072			Inspector		
		INVOICE				
Return this stub with payr	No other invoice will be n 30 days from date of invoice, ment to: NC Department of Labo , Raleigh, NC 27699-1101	your certificate becon		Invoice 5939 State Nbr: 1	Number 964	