



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593967

EQUIPMENT INSPECTED

State Number: 9311 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2100 Installed: 10/24/1979 Complied: 10/24/1979 Speed: 125
Volts: 240 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: AVERY COUNTY SCHOOLS, P.O. BOX 1360, NEWLAND, NC, 28657
Occupant: NEWLAND ELEMENTARY SCHOOL, 750 LINVILLE STREET, NEWLAND, NC, 28657

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
02/11/2009	Routine	Re-issued	4 - Henegar	AVERY	6

Violation Abatement Date: 03/13/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.11.3.2.1 Take steps to perform the annual relief valve test

Violations pointed out to: Ellis Ayers # 828-733-4911

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: AVERY COUNTY SCHOOLS, P.O. BOX 1360, NEWLAND, NC, 28657
Occupant: NEWLAND ELEMENTARY SCHOOL, 750 LINVILLE STREET, NEWLAND, NC,
28657

Invoice Number
593967

State Nbr: 9311
Date: 02/11/2009
Fee: \$175