



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593990

EQUIPMENT INSPECTED

State Number: 14194 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2100 Installed: 07/25/1991 Complied: 07/25/1991 Speed: 100
Volts: 208 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: ALEXANDER COUNTY SCHOOLS, 700 LILEDOWN ROAD, TAYLORSVILLE, NC, 28681
Occupant: BETHLEHEM ELEMENTARY SCHOOL, 7900 N.C. HWY 127, TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
02/17/2009	Routine	Re-issued	4 - Henegar	ALEXANDER	2

Violation Abatement Date: 03/19/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.5.7 Provide an oil use log maintained the machine room for systems where the part of cylinder and/or piping is not exposed for visible inspection.

Violations pointed out to: Dale Robertson # 828-635-8248

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ALEXANDER COUNTY SCHOOLS, 700 LILEDOWN ROAD, TAYLORSVILLE, NC, 28681
Occupant: BETHLEHEM ELEMENTARY SCHOOL, 7900 N.C. HWY 127, TAYLORSVILLE, NC, 28681

Invoice Number
593990

State Nbr: 14194
Date: 02/17/2009
Fee: \$175