



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
593993

EQUIPMENT INSPECTED

State Number: 21973 Type of Unit: Passenger Landings: 2 Manuf: THYSSEN KRUPP
Capacity: 2500 Installed: 06/08/2004 Complied: 07/01/2004 Speed: 100
Volts: 208 Floor to Floor: 1 to 2 Entrances: 1 Rope Size: 0
Owner: ANTIOCH BAPTIST CHURCH, 580 ANTIOCH CHURCH ROAD, TAYLORSVILLE, NC, 28681
Occupant: ANTIOCH BAPTIST CHURCH, 580 ANTIOCH CHURCH ROAD, TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date 02/17/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County Name ALEXANDER	County Code 2
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------------	------------------

Violation Abatement Date: 03/19/2009

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.5.7 Provide an oil use log maintained the machine room for systems where the part of cylinder and/or piping is not exposed for visible inspection.

Violations pointed out to: Alma Palmer # 828-632-2929

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ANTIOCH BAPTIST CHURCH, 580 ANTIOCH CHURCH ROAD, TAYLORSVILLE, NC, 28681
Occupant: ANTIOCH BAPTIST CHURCH, 580 ANTIOCH CHURCH ROAD, TAYLORSVILLE, NC, 28681

Invoice Number
593993

State Nbr: 21973
Date: 02/17/2009
Fee: \$175