N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
636030

EQUIPMENT INSPECTED

State Number: 22268	Type of Unit: Passenger	Landings: 3	Manuf: KONE
Capacity: 2500	Installed: 03/16/2004	Complied: 03/16/2004	Speed: 100
Volts: 208	Floor to Floor: 1 to 3	Entrances: 1	Rope Size: 0

Owner: NORTHWESTERN REGIONAL HOUSING, P.O. BOX 2510, BOONE, NC, 28607

Occupant: ELK PARK APARTMENTS, 256 ELK PARK SCHOOL ROAD, ELK PARK, NC, 28622

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County Name	County Code
02/26/2009	Routine	Re-issued	4 - Henegar	AVERY	6

Violation Abatement Date: 03/28/2009 VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

2.27.1.1.2	Take steps to place the in car emergency telephone in proper working order.
8.6.4.7.1	Hoistways and pits shall be kept free of dirt and rubbish.
8.11.3.2.1	Take steps to perform the annual relief valve test (DUE 11/08)

Violations pointed out to: Sarah Young # 828-733-8210 Inspector _____

INVOICE

No other invoice will be issued.
If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division, 1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: NORTHWESTERN REGIONAL HOUSING, P.O. BOX 2510, BOONE, NC, 28607
Occupant: ELK PARK APARTMENTS, 256 ELK PARK SCHOOL ROAD, ELK PARK, NC, 28622

Invoice Number
636030
State Nbr: 22268
Date: 02/26/2009
Fee: $175