

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm

Invoice Number 636036

		EQUIPMENT INS	PECTED		
State Number: 12864 Capacity: 2100 Volts: 480 Owner: ALEXANDER of Occupant: EAST ALEX	ty: 2100 Installed: 08/25/1988 480 Floor to Floor: 1 to 2 :: ALEXANDER COUNTY SCHOOLS, P.O. BOX 128, ant: EAST ALEXANDER MIDDLE, 1285 WHITE PLA		Landings: 2 Complied: 09/07/1988 Entrances: 1 ORSVILLE, NC, 28681 OAD, HIDDENITE, NC, 28636		Manuf: ASK Speed: 100 Rope Size: 0
INSPECTION INFORMATION					
Inspection Date 02/27/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County Name ALEXANDER	County Coo
	Date: 03/29/2009				
equipment into compliance	u in writing on Corrected te with current codes.		-		
2.14.1.5.1	Take steps to secure the ca	ar top emergency exit.			
Violations pointed out to:	Sheila Jenkins # 828-632	-7565		Inspector	
		INVOICE	 C		
	No other invoice				
If not paid within 30 days from date of invoice, your certificate beturn this stub with payment to: NC Department of Labor, Budget and Police 101 Mail Service Center, Raleigh, NC 27699-1101					oice Number 636036 r: 12864
	COUNTY SCHOOLS, P.0 ANDER MIDDLE, 1285 V			Date: Fee:	02/27/2009 \$175