



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm

Invoice Number
636114

EQUIPMENT INSPECTED

State Number: 5796	Type of Unit: Freight	Landings: 2	Manuf: REMCO
Capacity: 2000	Installed: 05/23/1967	Complied: 08/24/1967	Speed: 30
Volts: 220	Floor to Floor: 1 to 2	Entrances: 2	Rope Size: 0
Owner: ADAMS FUNERAL HOME LLC, P.O. BOX 937, TAYLORSVILLE, NC, 28681			
Occupant: ADAMS FUNERAL HOME, 307 MAIN AVENUE DRIVE, TAYLORSVILLE, NC, 28681			

INSPECTION INFORMATION

Inspection Date 03/25/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County Name ALEXANDER	County Code 2
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------------	------------------

VIOLATIONS FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

8.6.5.7 Provide an oil usage log.

Violations pointed out to: Mark Odom # 828-632-2291

Inspector _____

INVOICE

No other invoice will be issued.

If not paid within 30 days from date of invoice, your certificate becomes invalid.

Return this stub with payment to: NC Department of Labor, Budget and Purchasing Division,
1101 Mail Service Center, Raleigh, NC 27699-1101

Owner: ADAMS FUNERAL HOME LLC, P.O. BOX 937, TAYLORSVILLE, NC, 28681
Occupant: ADAMS FUNERAL HOME, 307 MAIN AVENUE DRIVE, TAYLORSVILLE, NC,
28681

Invoice Number
636114

State Nbr: 5796
Date: 03/25/2009
Fee: \$175