N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10026-36-0116
State Number
6017

EQUIPMENT INSPECTED

State Number: **6017**
Capacity: 3000
Landings: 2
Volts: 460

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 09/10/1968
Complied: 09/10/1968

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
CITY OF BURLINGTON
PO BOX 1358
BURLINGTON, NC, 27216

OCCUPANT
MUNICIPAL BUILDING
425 S LEXINGTON AVE
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
01/26/2010	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF BURLINGTON
PO BOX 1358
BURLINGTON, NC, 27216