



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10028-17-3929
State Number
13203

EQUIPMENT INSPECTED

State Number: 13203	Type of Unit: Passenger	Floor to Floor: G to 3
Capacity: 2000	Manuf: ASHEVILLE	Speed: 100
Landings: 3	Installed: 02/01/1990	Rope Size:
Volts: 480	Complied: 02/01/1990	Entrances: 1

OWNER

ARBORETUM BUILDING
WESLEY BRANCH RD
ASHEVILLE, NC, 28806

OCCUPANT

ARBORETUM BUILDING
WESLEY BRANCH RD
ASHEVILLE, NC, 28806

INSPECTION INFORMATION

Inspection Date 01/28/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4 Provide fire service light and alarm to work on firemens recall.

Items must be corrected by: 02/27/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBORETUM BUILDING
WESLEY BRANCH RD
ASHEVILLE, NC, 28806