



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10042-36-5530
State Number
24204

EQUIPMENT INSPECTED

State Number: 24204	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 2	Installed: 11/01/2006	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
MACINTOSH ON THE LAKE	CLUB HOUSE "LOCH RIDGE MANOR"	
4210 BONNAR BRIDGE	4210 BONNAR BRIDGE	
BURLINGTON, NC, 27244	BURLINGTON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 02/11/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.1.2.1	Provide a written maintenance program.
8.6.10.1	Update the monthly fire service log.
8.11.3.2.1	Perform the annual relief valve test

Items must be corrected by: 03/13/2010

Elevator Name: LOCH RIDGE MANOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rob d

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MACINTOSH ON THE LAKE
4210 BONNAR BRIDGE
BURLINGTON, NC, 27244