

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 10046-36-5257 State Number 25796

EQUIPMENT INSPECTED

State Number: 25796	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 12/23/2008	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
CHAD PORTERFIELD	WOODBURY PARK	
2004A ANTHONY ROAD	2929 CROUSE LANE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/15/2010	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

left elevator notification

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: n/a

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CHAD PORTERFIELD
2004A ANTHONY ROAD
BURLINGTON, NC, 27215