N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10048-36-0799
State Number
2916

EQUIPMENT INSPECTED

State Number: **2916**
Capacity: 500
Landings: 3
Volts: 220

Type of Unit: Dumbwaiter
Manuf: MATOT
Installed: 04/15/1957
Complied: 03/20/2001

Floor to Floor: B to 3
Speed: 50
Rope Size: 3/8
Entrances: 1

OWNER
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

OCCUPANT
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/17/2010	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215