



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10050-17-2964**  
State Number  
**9563**

EQUIPMENT INSPECTED

State Number: <b>9563</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: ASHEVILLE	Speed: 125
Landings: 3	Installed: 05/05/1980	Rope Size:
Volts: 480	Complied: 06/04/1980	Entrances: 1

OWNER

AB TECHNICAL COLLEGE  
340 VICTORIA RD  
ASHEVILLE, NC, 28801

OCCUPANT

AB TECHNICAL COLLEGE  
340 VICTORIA RD  
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 02/19/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations

Items must be corrected by: 02/19/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Rice

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COLLEGE  
340 VICTORIA RD  
ASHEVILLE, NC, 28801